State of Hawaii DEPARTMENT OF LAND AND NATURAL RESOURCES ENGINEERING DIVISION 1151 Punchbowl Street, Room 221 Honolulu, Hawaii 96813

ADDENDUM NO. 1

TO

Job No. 500CK30B MANA DRAG RACING STRIP IMPROVEMENTS PHASE 2 ELECTRICAL IMPROVEMENTS Wailuku, Maui, Hawaii

The items listed hereinafter are hereby made a part of the contract for the above project and shall govern the work, taking precedence over previously issued plans and specifications governing the items mentioned.

GENERAL INFORMATION

None

PROPOSAL

(PDF copies of the revised proposal can be downloaded from the HIePRO website.)

Proposal – DELETE Pages P-2 to P-7 in its entirety and REPLACE with the attached revised Pages P-2 to P-7.

SPECIFICATION

(PDF copies of the revised sections can be downloaded from the HIePRO website.)

Enclosed revised sections shall replace their respective existing sections in its entirety.

1. Notice to Bidders

CONSTRUCTION PLANS

(PDF copies of the plan sheets below can be downloaded from the HIePRO website.)

Drawing No.DescriptionC-101Revised location of new KIUC service, electrical upgrades and BMP's.E-100Revised alignment of new KIUC overhead service poles.

Mana Drag Racing Strip Improvements Phase 2 Electrical Upgrades Kauai, Hawaii Job No. 500CK30B E-101 Revised location of new KIUC service and electrical upgrades near existing shed.

Added handhole (EHH-20) and revised subsequent electrical handhole

numbering.

CONSTRUCTION PLANS (Continued)

CONSTRUCTION FLAMS (Continued)	
E-105	Revised location of new 3'x5' electrical handhole.
E-401	Revised electrical equipment layout to reflect new location of 3'x5' electrical
	handhole.
E-504	Revised riser pole detail. Added note to meter cabinet detail.
E-505	Revised cover plan.
E-601	Revised Switchboard 4A one-line diagram.
E-602	Revised meter cabinet one-line diagram.
E-603	Revised Spectator Area Distribution Diagram to include new EHH-20.
	Subsequent electrical handhole numbers revised.

QUESTIONS AND CLARIFICATIONS

- 1. Since a majority of the work involves the installation of underground duct lines and other non-wiring work, we request approval to bid as the general contractor with the understanding that we will subcontract all wiring and other work that is required to be performed by a licensed electrician to a subcontractor holding a C-13 license.
 - a. Response: Contractors holding an "A" General Engineering Contractor license will be allowed to bid on the project with a subcontractor holding a C-13 license.

Engineering Division

Chief Engineer